

OFFICE OF CIVIL SURGEON, SIRSA.

NO-OBJECTION CERTIFICATE

Ref No. CMO/208


Dated 16/11/2018

Certified that Satluj Public School, Barnala Road Sirsa, Which is run by Satluj Public School, Charitable Trust, Sirsa was inspected by Medical Officer Urban Dispensary HUDA 20-P, Sirsa on dated 16/11/2018 & reported that hygiene & sanitation of this school is satisfactory. The structure of this school is well ventilated. Facility of Potable Water, First Aid and separate toilets for Male & Female are available.


Total climate of this school is neat and clean. Health Department has no objection regarding this.


This certificate is to be reviewed after one year.

Counter Sign.



Civil Surgeon
Sirsa.

^{16.11.18}
Dy. Civil Surgeon
For Civil Surgeon, Sirsa.
for Civil Surgeon, Sirsa



Principal
Satluj Public School
Barnala Road, Sirsa

Public Health Engineering Department
WATER TESTING RESEARCH LABORATORY SIRSA (HARYANA)

Sender's Address _____ Satluj Public School, Barnala Road, Sirsa
Source of Sample:- R/o Water Satluj Public School
Collection by Sh. Raj pal
Date of Collection:- 02-08-2019 Date of Receipt :- 02-08-2019
Ref. No. ByhandDt.02-08-2019 Lab no:- 222-C/2019
Memo no :- 1880t 08/08/2019

Drinking Water Quality Standard(is :10500)

Physico Chemical Characteristics

(i) Appearance Clear (ii) Taste Normal (iii) Odour Normal (iv) Turbidity Clear

(The following values are expressed as mg/l)


S. No	Parameter	Result	Acceptable	Cause for Rejection
1	Total Dissolved Solids as Such(103-5C)	171	500 mg/l	2000
2	Total Hardness(as Ca Co ₃)	80	300 mg/l	600
3	Calcium (as Ca)	8.0	75 mg/l	200
4	Magnesium(as Mg)	14.4	30 mg/l	100
5	Total Alkalinity	40	200 mg/l	600
6	Iron (as Fe)	0.17	0.3 mg/l	1.0
7	Chlorides (as Cl)	80	250 mg/l	1000
8	Sulphates (as So ₄)	60	200 mg/l	400
9	Fluoride (as F)	0.04	1.0 mg/l	1.5
10	Nitrate (as NO ₃)	1.50	45 mg/l	No Relaxation
11	pH	7.9	6.5 to 8.5	No Relaxation
12	Residual Chlorine	Nil	0.2ppm	1.0ppm

OPINION

Remarks:-Water Sample Complies to IS-10500:2012(2nd Rev) .

- The Result given above are related to the sample as received and tested in PHED Distt Lab Sirsa
- The Test report can't be regenerated/ re-produced in Whole or part thereof without written permission of PHED Distt Lab Sirsa
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample lies with sender/collector of water sample.


Principal
Satluj Public School
Barnala Road, Sirsa


Chemist
Public Health Engineering
Water Testing Laboratory Sirsa